



**Certificado nº**  
*Certificate no.* **TAC-007/2017**

**Nome e morada do titular do certificado:**  
*Name and address of certificate holder:*

ISOTUBI, S. L.  
Poligono Ind. Santa Rita, Calle Mecanica, 6,  
08755 Castellbisbal – Barcelona, España

**Nome e morada do fabricante:**  
*Manufacturer's name and address:*

ISOTUBI, S. L. ISOTUBI, S. L.  
Poligono Ind. Santa Rita, Calle C/ Costa I Déu, 87  
Mecanica, 6, 08205 Sabadell – Barcelona  
08755 Castellbisbal – Barcelona España  
Espana

**Produto:**  
*Product:*

Tubos soldados de aço para aplicações sob pressão  
*Welded steel tubes for pressure purposes*

**Referências:**  
**Type references:**

De acordo com as características técnicas / *In accordance with technical characteristics*

**Marca(s) comercial(is):**  
*Trademark(s):*

NUMEPRESS, ISOTUBI

**Características técnicas:**  
*Technical characteristics:*

Aço/steel 1.4301; 1.4401 e/and 1.4404:  
Dimensões/Dimensions (mm x mm): 15,0x0,6; 15,0x1,0; 18,0x0,7;  
18,0x1,0; 22,0x0,7; 22,0x1,2; 28,0x0,8; 28,0x1,2; 35,0x1,0;  
35,0x1,5; 42,0x1,1; 42,0x1,5; 54,0x1,2; 54,0x1,5; 76,1x2,0;  
88,9x2,0; 108,0x2,0

Processo de fabrico / *Manufacturing process:* Soldadura com arco /  
*Arc - welded*

**Este produto está em conformidade com:**  
*This product is in conformity with:*

EN 10217-7:2014

**Relatórios de ensaios nº(s) / emitidos por:**  
*Test report(s) no. / issued by:*

20154001243/20-A / CATIM e/and 150178ENDBAR-OT0001-RT01 e  
SCI

**Informação adicional (se existir):**  
*Additional information (if any):*

---

**Este certificado é válido até:**  
*This certificate is valid until:*

2021-03-15

**e substitui o certificado nº:**  
*and supersedes certificate no:*

TAC-006/2016

**Data de emissão:**  
*Date of issue:*

2017-02-22

Francisco Barroca  
Diretor Geral / *General Manager*